

Clarifications Questions - Version 4

| Question | Answers |
|--|---|
| What is the power output required for the facility in kWh? | The kWh output will be dependent on the process and efficiency of the waste-to-energy plant; during the design phase, the Consultant will liaise and coordinate with the Port of Barbados concerning the minimum kWh required with integration of such into the design. |
| What type of facility does the client prefer to be constructed? | As stated the in Terms of Reference and explained in the pre-proposal meeting, the Client desires that a WtE Facility will operate with a Steam Rankine Cycle (SRC) System. |
| Are we allowed to use the same experts from the Design Phase to fill positions for the Construction Supervision and Commissioning Phase? | Yes |
| Is it permissible for the Consulting firm to propose the personnel of a construction company that plans to bid for the EPC contract and include them in their team as experts? | This would not be allowed. |
| Should Taxes and VAT should be included in the financial proposal | The Financial Proposal Forms FIN-1 and FIN-2 in Section 4 of the Request for Proposal (RFP) outlines how local taxes should be indicated. Please fill out these forms accordingly. As Form 2 states these local taxes shall be discussed and finalised at negotiations. |
| Are the forms the normal forms or are there customizations for this tender? Will you be making word version of the forms available? | The word version of the proposal forms will be shared in the procurement page. These forms are standard proposal Forms for consulting services funded by multilateral development banks (MDBs). |
| Is there scope to increase the project site? | At present there is no scope to increase the size of the project site. |

| | |
|--|--|
| <p>Kindly confirm if this requirement can be substituted with “experience in process or mechanical engineering related to not limited to, cranes, furnace, boiler, turbine and water steam system, APC system etc.;</p> | <p>No, the project is a WtE facility, and experience should relate to this project. However, any experience may be evaluated subject to its relevance to the position being proposed.</p> |
| <p>1. Kindly confirm if the site visit and pre proposal conference were mandatory 2. Would lack of attendance result in a consultant being ineligible to tender?</p> | <p>1. Attendance to the pre-proposal conference is not mandatory. 2.No</p> |
| <p>The Request of Proposal Letter (item 4) states a deadline of 16 Jan 2023 for informing you of our intention to bid. Is item 4 a disqualification criterion?</p> | <p>No Item 4 is not a disqualification Criterion. We have extended the date in Item 4 and issued an RFP Addendum.</p> |
| <p>Please can we have a summary of the waste stream, broken down by type of waste, volume of waste, and monthly (seasonal) amounts of waste. And, to learn if some of the wastes are source separated in the cruise ships and other Port facilities (i.e., organics wastes, plastics, etc.).</p> | <p>We have provided an Annex which summarises this information.</p> |
| <p>Who controls the garbage and what is the collections system? Is it government collected? Is there community commitment for the project? Will there be a power to purchase agreement for the EPC contract holder?</p> | <p>The Port controls the waste collection. As per the TOR the waste is collected in skips. The Port collects the waste. Yes there is community commitment to the project. The port have undertaken a Townhall meeting to inform the local community. No the facility will be transferred to the port to operate.</p> |